UL Product iQ™

MZQE.EX4211 - FIRE HOSE, LINED, UNCOUPLED, FOR MUNICIPAL AND INDUSTRIAL USE

Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use

See General Information for Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use

KEY FIRE HOSE CORP
2926 COLUMBIA HWY
DOTHAN, AL 36303-5406 USA

EX4211

"Proflo" 1-1/2, 2. 2-1/2 and 3 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to single-jacketed 250 psig service test pressure fire hose.

"Proflo" 4 and 5 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to double-jacketed 200 psig service test pressure fire hose.

"DuraFlo" 1-3/4 and 2-1/2 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to single-jacketed 250 psig service test pressure fire hose.

Single-jacketed fire hose, 1-1/2 in. size ("SP15"), 2 in. size ("SP20"), and 2-1/2 in. size ("SP25").

Double-jacketed fire hose, 1-1/2 in. size ("DP15"), 1-3/4 in. size ("DP17"), 2 in. size ("DP20"), 2-1/2 in. size *("DP25"), 3 in. size ("DP30"), 3-1/2 in. size ("DP35"), and *4 in. size ("DP40").

Last Updated on 2012-09-17

La presencia del nombre de una empresa o producto en esta base de datos no garantiza por sí misma que los productos así identificados hayan sido fabricados bajo el servicio de seguimiento de UL. Solo aquellos productos que lleven la marca UL deben considerarse como certificados y garantizados bajo el servicio de seguimiento de UL. Busque siempre la marca en el producto.

UL permite la reproducción del material contenido en el directorio de certificación en línea sujeta a las siguientes condiciones: 1. La información de la guía, las asambleas, las construcciones, los diseños, los sistemas y/o certificaciones (archivos) deben presentarse en su totalidad y de forma no engañosa, sin ninguna manipulación en los datos (o dibujos). 2. Debe aparecer la declaración "Reimpreso desde el directorio de certificaciones en línea con permiso de UL" junto al material extraído. Además, el material reimpreso debe incluir una nota de derechos de autor en el siguiente formato: "© 2020 UL LLC"

