MASTER FOAM

Self-Educting Foam Nozzle

Certificate of Compliance

to UL162 (1997)

Task Force Tips, Inc. certifies that the following Master Foam Nozzle Series meets the Proportioning Accuracy Requirements of UL162 (1997)

Actual calibrated rate for each setting and the foam concentrate used for calibration			
SETTING	**ACTUAL RATE**	**FOAM CLASS**	**UL-162 TOLERANCE**
1/4%	0.287%	A	.25 - .325%
1/2%	0.575%	A	.5 - .65%%
1%	1.15%	B	1 - 1.3%
3%	3.45%	B	3 - 3.9%
6%	6.5%	B	6 - 7.8%

All ZMF Series of
Master Foam Nozzles

Test data certified by Task Force Tips.
Details of foam used can be found in
TFT manual LIU-330 section 4.4

TASK FORCE TIPS
Delivers what our customers need, when they need it.

10001004 QM08 — ISO 9001:2008

TASK FORCE TIPS, INC